



Approval of the Trademark Trevira CS®

Zimmer + Rohde GmbH Zimmersmühlenweg 14-18 61440 Oberursel Germany

Application No.: 230405.2 / 230406.2 / 230407.2

Date of issue: 11.07.2023 **Valid until:** 16.06.2028

Article name: 10475
End use: Drapes
Square weight (g/m²): 93

According to customer specification

Composition of the raw materials: Polyester 100% **Composition of the fabric:** Previra CS 100%

The collection "10475" is granted approval for the trademark Trevira CS® for interior use.

The approval of the collection is based on the trademark test results of application no. 230405 v. 99 bianco / 230406 v. 49 magenta / 230407 v. 52 marrone.

This collection has been tested according to DIN 4102 part 1, 6.2 and thus also meet the requirements for fire class DIN 4102-B1.

The collection has been tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

The collection meets the requirements for class 1 according to EN 13773.

The collection meets also the requirements for class 1 according to the Italian Standards UNI 8456 and UNI 8457.

The collection meets also the requirements according to British Standard BS 5867 part 2 type C.

This collection also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

Indorama Ventures Fibers Germany GmbH (This document is valid without signature.)