



Date of Issue: 5/17/2023 Report Number: 23-001583

Revision Number:1

Date Order Received: 05/12/2023

For the Account of: Ado Goldkante GmbH & Co. KG Zimmersmuhlenweg 14-18

61440 Oberursel Germany

Client's	Identification:	

1053

CERTIFICATE OF TESTING

TEST PERFORMED: NFPA 701 Standard Methods of Fire Test for Flame Propagation of Textiles and Films 2019 – Test #1

TEST RESULTS

Specimen	Mass Initial (g)	Mass Final (g)	Mass Loss (%)	Drip Burn (s)	Afterflame (s)
1	12.5	8.7	30	0.0	0.0
2	12.5	8.5	32	0.0	0.0
3	12.3	9.7	21	0.0	0.0
4	12.3	8.8	28	0.0	0.0
5	12.1	8.9	26	0.0	0.0
6	12.3	9.6	22	0.0	0.0
7	12.4	9.1	27	0.0	0.0
8	12.4	9.0	27	0.0	0.0
9	12.3	8.9	28	0.0	0.0
10	12.5	8.6	31	0.0	0.0
Average	12.4	9.0	27	0.0	0.0

Approximate weight (oz	z./sq. yd): 6.1	Standard Deviation: 3.6	Average + 3 SD: 37.8
Product Configuration: Conditioning: ntended End-use (if kn	,	☐ Multi Layer for minimum 30 minutes rapery	\square 70 ±2°F & 65 ±2%RH for minimum 24 hours
1. Where fragme seconds per seconds per seconds per seconds and seconds are seconds as larger with the second are seconds as seconds. 2. Where the average be recorded as seconds are seconds. 2. CONCLUSION Bas	be recorded; however, it is not ents or residues of specimens to pecimen for the sample of 10 se erage weight loss of the 10 specimens will be listed as a failur ecimens do not demonstrate pe s passing this test and shall be	specimens, the material shall be r ecimens in a sample is greater tha e if it exceeds mean + 3 SD	mber continue to burn for more than an average of 2 recorded as failing. (Flaming Drip) an 40 percent, the material shall be recorded as failing. ther of the conditions indicated above, the material shall
CERTIFICATION I certify specified by the standar		btained after testing specimen in	accordance with the procedures and equipment
Authorized Signature			Date Order Completed: 05/17/2023

553 76th Street, Byron Center, MI 49315

P: 616-559-6123 E: testlab@applied-lab.com

Page 1 of 1