



Approval of the Trademark Trevira CS®

Zimmer + Rohde
Zimmersmühlenweg
61440 Oberursel
Germany

Application No.:	250164
Date of issue:	27.02.2025
Valid until:	27.02.2030
Article name:	JE069-1
End use:	Curtains
Square weight (g/m²):	79
According to customer specification	
Composition of the raw materials:	Polyester 100%
Composition of the fabric:	Trevira CS 100%

Yarn: Warp, 20 / 1 den Trevira® Type YM TEX. TRV DOBE DYE,
Yarn supplier TREVIRA
Weft, 25 / 4 den Trevira® Type 800Z TRV YARN,
Yarn supplier SI LIN
Weft, 18 / 2 Ne Trevira® Type TREVIRA FLAM Y,
Yarn supplier GÖL IPLIK
Weft, 8 / 1 Ne Trevira® Type TREVIRA FLAM Y,
Yarn supplier FILMAN MADE

The tested article JE069-1 with application no. 250164 is granted approval for the trademark Trevira CS® for interior use.

This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

The article meets the requirements for class 1 according to EN 13773.

Thus meets also the requirements for class 1 according to the Italian Standards UNI 8456 and UNI 8457.

Thus meets also the requirements according to British Standard BS 5867 part 2 type C.

This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

Indorama Ventures Fibers Germany GmbH
(This document is valid without signature.)

Indorama Ventures Fibers Germany GmbH, Trademark Service, Max-Fischer-Straße 11, 86399 Bobingen, Germany

E-Mail: trademarkservice.IVFG@de.indorama.net