



Approval of the Trademark Trevira CS®

Zimmer + Rohde GmbH
Zimmersmühlenweg 14-18
61440 Oberursel
Germany

Application No.:	200716.1
Date of issue:	10.12.2020
Valid until:	05.11.2025
Article name:	10653
End use:	Drapes
Square weight (g/m²):	105
According to customer specification	
Composition of the raw materials:	Polyester 100%
Composition of the fabric:	Trevira CS 100%

The tested article 10653 with application no. 200716.1 is granted approval for the trademark Trevira CS® for interior use. This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1. The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507. Thus meets also the requirements according to British Standard BS 5867 part 2 type C. Thus meets also the requirements for class 1 according to the Italian Standards UNI VF 8456 and UNI VF 8457. This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781). The article meets the requirements for class 1 according to EN 13773.

Trevira GmbH
(This document is valid without signature.)