



CERTIFICATE

CENTEXBEL TYPE TESTING | TEST REPORT N° 21.06075.09

According to report N° 21.06075.09, dated on 2/11/2021, we confirm that the below mentioned items were tested at CENTEXBEL with reference to **NF P 92-507 (2004) "Fire safety - Building - Interior fitting materials - Classification according to their reaction to fire"**.

The items show

Classification M1

When properly applied.

The evaluation of the burning behaviour is based on CENTEXBEL's evaluation scheme.

SAMPLES

10719

Various colours

Company

Ado Goldkante GmbH Co Kg

Zimmersmühlenweg 14-18

61440 OBERURSEL - GERMANY

This Certificate is valid until 2/11/2026

Centexbel | Technologiepark 70 | BE 9052 Gent | Belgium, 2/11/2021

Stijn Devaere, PhD
Director Services