



## Approval of the Trademark Trevira CS flex®

Zimmer + Rohde GmbH  
Zimmersmühlenweg 14-18  
61440 Oberursel  
Germany

<b>Application No.:</b>	250021.1
<b>Date of issue:</b>	17.02.2025
<b>Valid until:</b>	31.12.2025
<b>Article name:</b>	10722 CLAY
<b>End use:</b>	Curtains
<b>Square weight (g/m<sup>2</sup>):</b> according to customer specification	55
<b>Composition of the raw materials:</b>	100% Polyester
<b>Composition of the fabric:</b>	84% Trevira CS 16% Monofil dtex 22f1, otherss

The article 10722 CLAY has been tested under the Trevira trademark application no. 250021 and is granted approval for the trademark Trevira CS flex® for interior use.

The article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

Indorama Ventures Fibers Germany GmbH  
(This document is valid without signature.)