



## Limited Approval for the Trademark Trevira CS®

Zimmer + Rohde  
Zimmersmühlenweg  
61440 Oberursel  
Germany

|  |   |
|--|---|
| <b>Application No.:</b>  | 190413.1  |
| <b>Date of issue:</b>  | 21.06.2019  |
| <b>Valid until:</b>  | 19.06.2024  |
| <b>Article name:</b>   | 10722   |
| <b>End use :</b>   | Drapes<br>Curtains  |
| <b>Square weight (g/m<sup>2</sup>):</b><br>according to customer specification | 50  |
| <b>Composition of fabric:</b>  | Polyester 100%<br>75% Trevira CS / 25% Polyester  |
| <b>Yarns:</b>  | Warp, 22 f 1 x 1 dtex Trevira® Type 695V,<br>Yarn supplier TORCITURA PADANA<br>Weft, 22 f 1 x 1 dtex Trevira® Type 693O,<br>Yarn supplier TORCITURA PADANA<br>Weft, 300 f 1 x 1 dtex Trevira® Type 691,<br>Yarn supplier TREVIRA<br>Weft, 350 f 256 x 1 dtex Trevira® Type 691,<br>Yarn supplier LEITSU |

The tested article 10722 color white/ beige/ grey with application no. 190413.1 is granted approval for the trademark Trevira CS® for interior use. This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

Trevira GmbH  
(This document is valid without signature.)