



## Approval of the Trademark Trevira CS flex®

Zimmer + Rohde GmbH  
Zimmersmühlenweg 14-18  
61440 Oberursel  
Germany

|  |                                      |
|--|--------------------------------------|
| <b>Application No.:</b>  | 230951.1                             |
| <b>Date of issue:</b>  | 21.02.2024                           |
| <b>Valid until:</b>  | 16.01.2029                           |
| <b>Article name:</b>   | 10805                                |
| <b>End use:</b>  | Drapes                               |
| <b>Square weight (g/m<sup>2</sup>):</b><br>according to customer specification | 81                                   |
| <b>Composition of the raw materials:</b>                                       | 100 % Polyester                      |
| <b>Composition of the fabric:</b>  | 90,5 % Trevira CS<br>9,5 % Tape yarn |

The article 10805 has been tested under the Trevira trademark application no. 230951 and is granted approval for the trademark Trevira CS flex® for interior use.

The article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

The article was tested according to EN 1101 and thus also meets the requirements for class 1 according to EN 13773.

Indorama Ventures Fibers Germany GmbH  
(This document is valid without signature.)