



## Approval of the Trademark Trevira CS flex®

Zimmer + Rohde GmbH  
Zimmersmühlenweg 14-18  
61440 Oberursel  
Germany

<b>Application No.:</b>	230853.2 / 230854.2 / 230855.2
<b>Date of issue:</b>	20.12.2023
<b>Valid until:</b>	05.12.2028
<b>Article name:</b>	10810
<b>End use:</b>	Drapes Curtains
<b>Square weight (g/m<sup>2</sup>):</b> according to customer specification	170
<b>Composition of the raw materials:</b>	100% Polyester
<b>Composition of the fabric:</b>	94% Trevira CS 6% Tape Yarn

The collection "10810" is granted approval for the trademark Trevira CS flex® for interior use.

The approval of the collection is based on the trademark test results of application no. 230853 col A00 / 230854 col A06 / 230855 col A04.

This collection has been tested according to DIN 4102 part 1, 6.2 and thus also meet the requirements for fire class DIN 4102-B1.

This collection has been tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507. This collection has been tested according to EN 1101 and thus also meets the requirements for class 1 according to EN 13773.

Indorama Ventures Fibers Germany GmbH  
(This document is valid without signature.)