



Approval of the Trademark Trevira CS flex®

Zimmer + Rohde GmbH
Zimmersmühlenweg 14-18
61440 Oberursel
Germany

Application No.:	230853.2 / 230854.2 / 230855.2
Date of issue:	20.12.2023
Valid until:	05.12.2028
Article name:	10810
End use:	Drapes Curtains
Square weight (g/m²): according to customer specification	170
Composition of the raw materials:	100% Polyester
Composition of the fabric:	94% Trevira CS 6% Tape Yarn

The collection "10810" is granted approval for the trademark Trevira CS flex® for interior use.

The approval of the collection is based on the trademark test results of application no. 230853 col A00 / 230854 col A06 / 230855 col A04.

This collection has been tested according to DIN 4102 part 1, 6.2 and thus also meet the requirements for fire class DIN 4102-B1.

This collection has been tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507. This collection has been tested according to EN 1101 and thus also meets the requirements for class 1 according to EN 13773.

Indorama Ventures Fibers Germany GmbH
(This document is valid without signature.)