



Limited Approval for the Trademark Trevira CS®

Zimmer + Rohde GmbH
Zimmersmühlernweg 14-18
61440 Oberursel
Germany

Application No.: 190942.1
Date of issue: 11.10.2019
Valid until: 16.09.2024

Article name: 10841
End use : Curtains
Square weight (g/m²): 233
according to customer specification
Composition of fabric: Polyester 100%
95% Trevira CS / 5% Polyester cationic

Yarns: Warp, 30 / 1 Ne Trevira® Type %90 TRV 510 KTY,
Yarn supplier FILMANMADE
Weft, 18 / 2 Ne Trevira® Type TREVIRA FLAM SPUN Y,
Yarn supplier GÖL IPLIK
Weft, 410 / 1 den Trevira® Type TEX TRV+KTY,
Yarn supplier TREVIRA+TASDELEN

The tested article 10841 with application no. 190942.1 is granted approval for the trademark Trevira CS® for interior use. This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

The article was tested according to EN 1101 and thus also meets the requirements for class 1 according to EN 13773.

Trevira GmbH
(This document is valid without signature.)