



## Approval of the Trademark Trevira CS®

ZIMMER + ROHDE  
Zimmersmühlenweg 14-18  
61440 Oberursel  
Germany

**Application No.:** 200177.1  
**Date of issue:** 01.04.2020  
**Valid until:** 25.03.2025

**Article name:** 10880  
**End use:** Curtains  
**Square weight (g/m<sup>2</sup>):** 170  
**According to customer specification**  
**Composition of the raw materials:** Polyester 100%  
**Composition of the fabric:** Trevira CS 100%

**Yarn:** Warp, 70 / 24 den Trevira® Type 800Z YM TREVIRA Y.,  
Yarn supplier TREVIRA  
Weft, 2050/1 den Trevira® Type 2050 DEN TRV FANCY Y,  
Yarn supplier TREVIRA+TASDELEN+FILMANMADE

The tested article 10880 with application no. 200177.1 is granted approval for the trademark Trevira CS® for interior use.

This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

Thus meets also the requirements according to British Standard BS 5867 part 2 type C.

Thus meets also the requirements for class 1 according to the Italian Standards UNI VF 8456 and UNI VF 8457.

This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

The article was tested according to EN 1101 and thus also meets the requirements for class 1 according to EN 13773.

Trevira GmbH  
(This document is valid without signature.)