



## Approval of the Trademark Trevira CS®

Zimmer + Rohde GmbH  
Zimmersmühlenweg 14-18  
61440 Oberursel  
Germany

**Application No.:** 220615.2 / 220616.2 / 220617.2  
**Date of issue:** 31.08.2022  
**Valid until:** 01.08.2027

**Article name:** 10935  
**End use:** Curtains  
**Square weight (g/m<sup>2</sup>):** 315  
**According to customer specification**  
**Composition of the raw materials:** Polyester 100%  
**Composition of the fabric:** Trevira CS 100%

The collection "10935" is granted approval for the trademark Trevira CS® for interior use.

The approval of the collection is based on the trademark test results of application no. 220615 col. CANDIDO (891) / 220616 col. SERALDO (695) / 220617 col. TAPIRO (826). This collection has been tested according to DIN 4102 part 1, 6.2 and thus also meet the requirements for fire class DIN 4102-B1.

The collection has been tested according to the French Standard NF P 92-503 (Brûleur électrique) and thus also meets the requirements for class M1 according to NF P 92-504, 92-505 and 92-507.

Thus meets also the requirements according to British Standard BS 5867 part 2 type C.

Thus meets also the requirements for class 1 according to the Italian Standards UNI 8456 and UNI 8457.

This collection also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

The collection meets the requirements for class 1 according to EN 13773.

Trevira GmbH  
(This document is valid without signature.)