



## Approval of the Trademark Trevira CS®

Zimmer + Rohde GmbH  
Zimmersmühlenweg 14-18  
61440 Oberursel  
Germany

<b>Application No.:</b>	220354.1 / 220355.1 / 220256.1
<b>Date of issue:</b>	15.06.2022
<b>Valid until:</b>	16.05.2027
<b>Article name:</b>	10941
<b>End use:</b>	Drapes
<b>Square weight (g/m<sup>2</sup>):</b>	98
According to customer specification	
<b>Composition of the raw materials:</b>	Polyester 100%
<b>Composition of the fabric:</b>	Trevira CS 100%

The collection "10941" is granted approval for the trademark Trevira CS® for interior use.

The approval of the collection is based on the trademark test results of application no. 220354 col. cream / 220355 col. blue / 220356 col. burgundy.

This collection has been tested according to DIN 4102 part 1, 6.2 and thus also meet the requirements for fire class DIN 4102-B1.

This collection has been tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

This collection meets the requirements for class 1 according to EN 13773.

This collection meets also the requirements for class 1 according to the Italian Standards UNI 8456 and UNI 8457.

This collection meets also the requirements according to British Standard BS 5867 part 2 type C.

This collection also meets the requirements according to the North American standard

NFPA 701: 2010 Test Method #1

(based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

Trevira GmbH  
(This document is valid without signature.)

Trevira GmbH, Trademark Service, Max-Fischer-Straße 11, 86399 Bobingen, Germany  
E-Mail: [trademark.service@trevira.com](mailto:trademark.service@trevira.com)