



## Approval of the Trademark Trevira CS®

Zimmer + Rohde GmbH  
Zimmersmühlenweg 14-18  
61440 Oberursel  
Germany

**Application No.:** 220403.1 / 220404.1 / 220405.1  
**Date of issue:** 01.07.2022  
**Valid until:** 21.06.2027

**Article name:** 10942  
**End use:** Drapes  
**Square weight (g/m<sup>2</sup>):** 433  
**According to customer specification**  
**Composition of the raw materials:** Polyester 100%  
**Composition of the fabric:** Trevira CS 100%

The collection "10942" is granted approval for the trademark Trevira CS® for interior use.

The approval of the collection is based on the trademark test results of application no. 220403 col. cream / 220404 col. blue / 220405 col. red.

This collection has been tested according to DIN 4102 part 1, 6.2 and thus also meet the requirements for fire class DIN 4102-B1.

The collection has been tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

The collection has been tested according to EN 1101 and thus also meets the requirements for class 1 according to EN 13773.

This collection meets also the requirements for class 1 according to the Italian Standards UNI 8456 and UNI 8457.

This collection meets also the requirements according to British Standard BS 5867part 2 type C.

Trevira GmbH  
(This document is valid without signature.)