



Indorama Ventures Fibers Germany GmbH

Trademark Service

Max-Fischer-Str. 11

86399 Bobingen, Germany

trademarkservice.IVFG@de.indorama.net

Tel. +49 8234 9688 1673

www.indoramaventures.com



Approval of the Trademark Trevira CS®

Zimmer + Rohde GmbH
Zimmersmühlenweg 14-18
61440 Oberursel
Germany

Application No.: 240880.2 / 240881 / 240882

Date of issue: 26.01.2026

Valid until: 06.12.2029

Article name: 11019

Color: various

End use: Drapes

Square weight (g/m²): 62

According to customer specification

Composition of the raw materials: 100% Polyester

Composition of the fabric: 100% Trevira CS

The collection "11019" is granted approval for the trademark Trevira CS® for interior use.

The approval of the collection is based on the trademark test results of application no.:

240880 col. SCURA V216 / 240881 col. MEDIO V05 / 240882 col. CHIARO V03.

These articles have been tested according to DIN 4102 part 1, 6.2 and thus also meet the requirements for fire class DIN 4102-B1.

The collection was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

The collection meets the requirements for class 1 according to EN 13773.

The collection meets also the requirements for class 1 according to the Italian Standards UNI 8456 and UNI 8457.

The collection meets also the requirements according to British Standard BS 5867 part 2 type C.

The collection meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

INDORAMA
VENTURES

Indispensable Chemistry





The collection can also meet the requirements according to FAR/JAR/CS 25.853 App. F to part 25, part I, § (a), (1) (ii) (vertical test, ignition time 12 sec).

Indorama Ventures Fibers Germany GmbH
(This document is valid without signature.)

240880.2

