



Approval of the Trademark Trevira CS®

ADO Goldkante GmbH & Co. KG Zimmersmühlenweg 14-18 61440 Oberursel Germany

 Application No.:
 220749.3 / 230068.3 / 230069.3

 Date of issue:
 13.03.2023

 Valid until:
 13.10.2027

Article name:1120End use:DrapeSquare weight (g/m²):197According to customer specification197Composition of the raw materials:PolyeComposition of the fabric:Trevit

Drapes 197 Polyester 100% Trevira CS 100%

The collection "1120" is granted approval for the trademark Trevira CS® for interior use.

The approval of the collection is based on the trademark test results of application no. 220749 col. cream / 230068 col. red / 230069 col. black. This collection has been tested according to DIN 4102 part 1, 6.2 and thus also meet the requirements for fire class DIN 4102-B1.

The collection has been tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

The collection meets the requirements for class 1 according to EN 13773.

The collecton meets also the requirements for class 1 according to the Italian Standards UNI 8456 and UNI 8457.

The collection meets also the requirements according to British Standard BS 5867 part 2 type C.

This collection also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

Trevira GmbH (This document is valid without signature.)

> Trevira GmbH, Trademark Service, Max-Fischer-Straße 11, 86399 Bobingen, Germany E-Mail: <u>trademark.service@trevira.com</u>