



Approval of the Trademark Trevira CS®

ADO Goldkante GmbH & Co. KG Zimmersmühlenweg 14-18 61440 Oberursel Germany

 Application No.:
 200824.1

 Date of issue:
 04.12.2020

 Valid until:
 27.11.2025

Article name: 3145
End use: Curtains
Square weight (g/m²): 34

According to customer specification

Composition of the raw materials: Polyester 100% Trevira CS 100%

The tested article 3145 with application no. 200824.1

is granted approval for the trademark Trevira CS® for interior use.

This article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507. Thus meets also the requirements according to British Standard BS 5867 part 2 type C.

Thus meets also the requirements for class 1 according to the Italian Standards UNI VF 8456 and UNI VF 8457.

The article meets the requirements for class 1 according to EN 13773.

Trevira GmbH

(This document is valid without signature.)