

CERTIFICATE CENTEXBEL TYPE TESTING | TEST REPORT N° 23.05804.05 According to report N° 23.05804.05, dated on 13/12/2023, we confirm that the below mentioned items were tested at CENTEXBEL with reference to NF P 92-507 (2004) "Fire safety - Building -Interior fitting materials - Classification according to their reaction to fire". The item shows **Classification M1** Provided that it is properly applied. The evaluation of the burning behaviour is based on CENTEXBEL's evaluation scheme. SAMPLES 3153 Various colours Company Ado Goldkante GmbH & Co. Kg Zimmersmühlenweg 14-18 61440 OBERURSEL GERMANY This Certificate is valid until 13/12/2028 Centexbel | Technologiepark 70 | BE 9052 Gent | Belgium, 13/12/2023 Jan Laperre General Manage





ADO Goldkante GmbH & Co. KG Zimmersmühlenweg 14-18 61440 OBERURSEL Germany

Your notice of 27-10-2023

Your reference

Date 13-12-2023

Analysis Report 23.05804.05

Required tests :

NF P92-507 (2004)

| Sample id | Information given by the client | Date of receipt |
|-----------|---------------------------------|-----------------|
| T2324634 | 3153 - col. 200 | 27-10-2023 |

freelle

Gina Créelle Order responsible

This report may be reproduced, as long as it is presented in its entire form, without written permission of Centexbel. The results of the analysis cover the received samples. Centexbel is not responsible for the representativeness of the samples. In assessing compliance with the specifications, we did not take into account the uncertainty on the test results.



CENTEXBEL • textile competence centre • www.centexbel.be • www.vkc.be

GENT • Technologiepark 70 • BE-9052 Zwijnaarde, Belgium • phone +32 9 220 41 51 • fax +32 9 220 49 55 • gent@centexbel.be GRÂCE-HOLLOGNE • Rue du Travail 5 • BE-4460 Grâce-Hollogne, Belgium • phone +32 4 296 82 00 • g-h@centexbel.be KORTRIJK • Etienne Sabbelaan 49 • BE-8500 Kortrijk, Belgium • phone +32 56 29 27 00 • fax +32 56 29 27 01 • info@vkc.be VAT BE 0459.218.289 • IBAN BE44 2100 4729 6545 • BIC GEBABEBB Digitally signed by Centexbel



Analysis Report 23.05804.05 Date 13-12-2023 Page 2/5

Samples

T2324634 3153 - col. 200



Ƴ in f

0



Reference: T2324634 - 3153 - col. 200

Classification of materials according to their reaction to fire - "Electric burner"

| Date of ending the test | 11-12-2023 |
|-----------------------------|------------------------|
| Standard used | NF P92-503 (1995) |
| Product standard | NF P92-507 (2004) |
| Deviation from the standard | - |
| Dimension of the specimens | 600 mm x 180 mm x 1 mm |
| Weight (g/m^2) | 132 |

The test specimens have not been cleaned nor submitted to an accelerated ageing procedure

| 0 1 | ۰. | • | • |
|------|----|-----|-----|
| Cond | 11 | 10n | ing |
| | | | 0 |

23°C, relative humidity 50% Minimum 7 days or until constant mass is achieved

| | Ler | Length | | dth |
|--------------------------------------------|--------|--------|--------|--------|
| | Face A | Face B | Face A | Face B |
| Hole formation | yes | yes | yes | yes |
| Max. afterflame time (s) | 0 | 0 | 0 | 0 |
| Afterglow | no | no | no | no |
| Afterglow with propagation in area > 25 cm | | no | no | no |
| Damaged length (cm) | | 17.5 | 16.0 | 21.0 |
| Damaged width (cm) in area >45 cm | 0 | 0 | 0 | 0 |
| Flaming molten droplets | no | no | no | no |
| Non-flaming molten droplets | yes | no | no | yes |
| Flaming debris | no | no | no | no |
| Non-flaming debris | no | no | no | no |
| Average damaged length (cm) | 18.5 | | | |
| Average damaged width (cm) | 0 | | | |
| in area > 45 cm | | | | |



Reference: T2324634 - 3153 - col. 200

Classification of materials according to their reaction to fire - "Flame persistence test"

| Date of ending the test | 12-12-2023 |
|-----------------------------|------------------------|
| Standard used | NF P92-504 (1995) |
| Product standard | NF P92-507 (2004) |
| Deviation from the standard | - |
| Dimension of the specimens | 460 mm x 230 mm x 1 mm |
| Weight (g/m ²) | 132 |

The test specimens have not been cleaned nor submitted to an accelerated ageing procedure

| Conditioning | 23°C, relative humidity 50% |
|--------------|---------------------------------------------------|
| | Minimum 7 days or until constant mass is achieved |

Each test has been carried out with a flame application time of 5s.

| | Length | | Width | |
|--------------------------------------------|--------|--------|--------|--------|
| | Face A | Face B | Face A | Face B |
| #1 | * | * | * | * |
| #2 | * | * | * | * |
| #3 | * | * | * | * |
| #4 | * | * | * | * |
| #5 | * | * | * | * |
| #6 | * | * | * | * |
| #7 | * | * | * | * |
| #8 | * | * | * | * |
| #9 | * | * | * | * |
| #10 | * | * | * | * |
| Flaming debris no Non-flaming debris no | | | | |

*: afterflame time ≤ 2 s > 2 s: afterflame time > 2 s and ≤ 5 s > 5 s: afterflame time > 5 s



Reference: T2324634 - 3153 - col. 200

Classification of materials according to their reaction to fire - "Test for melting materials"

| Date of ending the test | 13-12-2023 |
|-----------------------------|----------------------|
| Standard used | NF P92-505 (1995) |
| Product standard | NF P92-507 (2004) |
| Deviation from the standard | - |
| Dimension of the specimens | 70 mm x 70 mm x 1 mm |
| Number of layers | 3 |
| Weight (g/m ²) | 132 |

The test specimens have not been cleaned nor submitted to an accelerated ageing procedure

| Conditioning | 23°C, relative humidity 50% |
|--------------|---------------------------------------------------|
| | Minimum 7 days or until constant mass is achieved |

Four specimens, two on both sides, have been tested .

| | | First | Non-flaming | Flaming | Ignition cotton | Mass |
|----|----------|--------------|-------------|---------|-----------------|------|
| | | ignition (s) | debris | debris | wool | (g) |
| #2 | l face A | * | yes | no | no | 2.0 |
| #2 | 2 face A | * | yes | no | no | 2.1 |
| #3 | 3 face B | * | yes | no | no | 2.1 |
| #4 | face B | * | yes | no | no | 2.1 |

* no ignition

Classification M1