



Approval of the Trademark Trevira CS®

ADO Goldkante GmbH & Co.KG
Zimmersmühlenweg 14-18
61440 Oberursel
Germany

Application No.:	200608.2 / 200426.2 / 200427.2 / 200428.2
Date of issue:	30.09.2020
Valid until:	28.09.2025
Article name:	3172
End use:	Drapes
Square weight (g/m²):	93
According to customer specification	
Composition of the raw materials:	Polyester 100%
Composition of the fabric:	Trevira CS 100%

The collection "3172" is granted approval for the trademark Trevira CS® for interior use.

The approval of the collection is based on the approval with the application no. 200608.2 col. 1998/ 200426.2 col. 1020 / 200427.2 col. 1095 / 200428.2 col. 1557. This collection has been tested according to DIN 4102 part 1, 6.2 and thus also meet the requirements for fire class DIN 4102-B1.

This collection has been tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

The collection meets the requirements for class 1 according to EN 13773.

The collection also the requirements according to British Standard BS 5867part 2 type C.

The collection meets also the requirements for class 1 according to the Italian Standards UNI VF 8456 and UNI VF 8457.

The collection also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

The collection qualifies for class B-s1, d0 according to the European Standard EN 13501-1. Trevira CS has been approved by the DIBt with the General Building Inspectorate Approval, Approval No. Z-56.25-3573 dd. 24 April 2018.

Trevira GmbH
(This document is valid without signature.)

Trevira GmbH, Trademark Service, Max-Fischer-Straße 11, 86399 Bobingen, Germany
E-Mail: trademark.service@trevira.com