



## Approval of the Trademark Trevira CS®

Zimmer + Rohde GmbH  
Zimmersmühlenweg 14-18  
61440 Oberursel  
Germany

|                                          |                 |
|------------------------------------------|-----------------|
| <b>Application No.:</b>                  | 240066.1        |
| <b>Date of issue:</b>                    | 07.03.2024      |
| <b>Valid until:</b>                      | 06.03.2029      |
| <b>Article name:</b>                     | 3544            |
| <b>End use:</b>                          | Curtains        |
| <b>Square weight (g/m²):</b>             | 85              |
| According to customer specification      |                 |
| <b>Composition of the raw materials:</b> | Polyester 100%  |
| <b>Composition of the fabric:</b>        | Trevira CS 100% |

The article 3544 has been tested under the Trevira trademark application no. 240066 (col white/grey stripes) and is granted approval for the trademark Trevira CS® for interior use.

The article was tested according to DIN 4102 part 1, 6.2 and thus also meets the requirements for fire class DIN 4102-B1.

The article was tested according to the French Standard NF P 92-504 (Propagation de flamme) and thus also meets the requirements for class M1 according to NF P 92-503, 92-505 and 92-507.

The article meets the requirements for class 1 according to EN 13773.

Thus meets also the requirements for class 1 according to the Italian Standards UNI 8456 and UNI 8457.

Thus meets also the requirements according to British Standard BS 5867 part 2 type C.

This article also meets the requirements according to the North American standard NFPA 701: 2010 Test Method #1 (based on the Test Reports Govmark, New York No. 2-94779, 2-94780, 2-94781).

Indorama Ventures Fibers Germany GmbH  
(This document is valid without signature.)